10 September 2013

ADDENDUM No 4

To Drawings prepared by:

UCI ARCHITECTS, INC.
1630 Pine Street
Philadelphia, PA 19103

For the Project: CCP West Building Fourth Floor Renovations
Project No.: 911

I. INSTRUCTIONS

A. All Work preformed under this Supplement shall be subject to the General Conditions of the Contract in connection with the Project.

II. DRAWINGS

A. The following items describe modifications to the Contract Drawings. Contractor is directed to add, or remove and replace the notations as indicated, or provide the work described herein.

1. Drawing CL-CS-1: REVISE package title.
2. Drawing CL-CS-2: REVISE drawing list.
3. Drawing CLE-104.A: ADD fire alarm devices and notes for scope of work.
4. Drawing CLE-104.B: ADD fire alarm devices and notes for scope of work.
5. Drawing CLE-104.C: ADD fire alarm devices and notes for scope of work.

III. SPECIFICATIONS

A. The following items are changes to specifications sections and describe a change in scope of the Contractor's Work. Contractor is directed to add, or remove and replace the sections indicated, or provide the work described herein.

1. Specification Section 00000 - Project Manual Cover:
   a. Replace this document in its entirety with the attached document.

2. Specification Section 00010 Table of Contents:
   a. Replace this document in its entirety with the attached document.

3. Specification Section 00015 List of Drawings:
   a. Replace this document in its entirety with the attached document.

4. Specification Section 08710 – Door Hardware:
    a. Replace this document in its entirety with the attached document to:
        1) ADD self contained electronic locks
        2) REVISE acceptable door hardware manufactures.

III. QUESTIONS AND RESPONSES

B-016: Who removes demo material off site for each trade?

Response: Each respective Prime is responsible for removing their waste material, demolition or otherwise, from the site (the fourth floor construction area) to the construction dumpster. The General Trades contractor will provide and maintain the construction dumpster.

B-017: Who supplies and installs the VFD's?

Response: Mechanical contractor shall provide and install VFD

- END OF ADDENDUM No 4 -